NDEP-BAPC PENALTY RECOMMENDATIONS - December 4, 2013

TAB NO.	COMPANY NAME	VIOLATION & PENALTY SUMMARY	NOAV NUMBER	RECOMMENDED PENALTY
A	NV Energy, Reid Gardner Generating Station, Clark County	NOAV 2452 Violation: Failure to comply with a permitted emission limit during a compliance source test Emission Limit: 0.03 lbs/MMbtu test result: 0.043 lbs/MMbtu Emission Unit: Unit #4 Steam Boiler Base Penalty: \$7,500, for Major Source failing for a "major" pollutant Magnitude (Multiplier): Moderate (1.43x) Violation History (Adjustment): 1 violation within past 5 years = 5% Total Penalty: (\$7,500 x 1.43) + (10,725 x 5%) = \$11,255	2452	\$11,255
В	El Sueno Resort and Casino, Nye County	NOAV 2165 Violation: Failure to apply for and obtain an air quality operating permit. Requirement: Apply for and obtain a Surface Area Disturbance permit for any project that disturbs over 5 acres. Base Penalty: \$500 plus \$50 per acre of disturbance Magnitude (Multiplier): 19 Acres Violation History (Adjustment): N/A Total Penalty: \$500 + (19 x \$50) = \$1,450	2165	\$1,450
С	Galtar LLC, Nye County	NOAV 2141 Violation: Failure to apply for and obtain an air quality operating permit. Requirement: Apply for and obtain a Surface Area Disturbance permit for any project that disturbs over 5 acres. Base Penalty: \$500 plus \$50 per acre of disturbance Magnitude (Multiplier): 200 Acres Violation History (Adjustment): N/A Total Penalty: \$500 + (200 x \$50) = \$10,500	2141	\$10,500